

OliNo Energy BV

Operator Marcel van der Steen  
 Telephone  
 Fax  
 e-Mail marcel@olino.org

## TDE-lighttech H4284 2700 frost cover / UGR-Table

Luminaire: TDE-lighttech H4284 2700 frost cover  
 Lamps: 1 x LED

<b>Glare Evaluation According to UGR</b>											
$\rho$ Ceiling	70	70	50	50	30	70	70	50	50	30	
$\rho$ Walls	50	30	50	30	30	50	30	50	30	30	
$\rho$ Floor	20	20	20	20	20	20	20	20	20	20	
Room Size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	19.8	21.0	20.3	21.6	22.2	18.3	19.5	18.9	20.1	20.8
	3H	22.3	23.5	23.0	24.1	24.8	20.2	21.3	20.8	21.9	22.6
	4H	23.6	24.6	24.2	25.3	26.0	20.9	22.0	21.6	22.6	23.4
	6H	24.8	25.8	25.4	26.4	27.2	21.5	22.5	22.2	23.2	23.9
	8H	25.3	26.3	26.0	26.9	27.7	21.7	22.7	22.4	23.3	24.1
	12H	25.9	26.8	26.6	27.5	28.3	21.9	22.8	22.6	23.5	24.3
4H	2H	20.3	21.3	20.9	22.0	22.7	19.2	20.3	19.9	20.9	21.7
	3H	23.1	24.0	23.8	24.7	25.5	21.4	22.3	22.1	23.0	23.7
	4H	24.6	25.4	25.3	26.1	26.9	22.3	23.1	23.0	23.8	24.6
	6H	26.0	26.7	26.7	27.4	28.3	23.0	23.8	23.8	24.5	25.3
	8H	26.6	27.3	27.4	28.0	28.9	23.3	24.0	24.1	24.7	25.6
	12H	27.3	27.9	28.0	28.7	29.5	23.6	24.2	24.3	24.9	25.8
8H	4H	24.9	25.6	25.6	26.3	27.2	23.1	23.8	23.8	24.5	25.3
	6H	26.6	27.1	27.3	27.9	28.8	24.1	24.7	24.9	25.4	26.3
	8H	27.4	27.9	28.2	28.7	29.6	24.6	25.1	25.3	25.8	26.8
	12H	28.3	28.7	29.1	29.5	30.4	24.9	25.4	25.7	26.2	27.1
12H	4H	24.9	25.6	25.7	26.3	27.2	23.3	23.9	24.0	24.6	25.5
	6H	26.7	27.2	27.4	28.0	28.9	24.5	25.0	25.2	25.7	26.6
	8H	27.6	28.1	28.4	28.8	29.8	25.0	25.5	25.8	26.3	27.2
Variation of the observer position for the luminaire distances S											
S = 1.0H	+0.1 / -0.1					+0.1 / -0.1					
S = 1.5H	+0.2 / -0.2					+0.2 / -0.2					
S = 2.0H	+0.3 / -0.4					+0.3 / -0.5					
Standard table	BK11					BK08					
Correction Summand	13.4					9.5					
Corrected Glare Indices referring to 740lm Total Luminous Flux											

The UGR values have been calculated according to CIE Publ. 117 Spacing-to-Height-Ratio = 1.00.