

Operator  
Telephone  
Fax  
e-Mail

## Lagotronics 94507008 DecaLED Downlight Wave-8S White 8W 3000°K CRI90 / UGR-Table

Luminaire: Lagotronics 94507008 DecaLED Downlight Wave-8S White 8W 3000°K CRI90  
Lamps: 1 x LED

<b>Glare Evaluation According to UGR</b>											
ρ Ceiling		70	70	50	50	30	70	70	50	50	30
ρ Walls		50	30	50	30	30	50	30	50	30	30
ρ Floor		20	20	20	20	20	20	20	20	20	20
Room Size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	17.5	18.3	17.7	18.5	18.7	17.5	18.3	17.7	18.5	18.7
	3H	17.4	18.1	17.6	18.3	18.6	17.4	18.1	17.6	18.3	18.6
	4H	17.3	18.0	17.6	18.2	18.5	17.3	18.0	17.6	18.2	18.5
	6H	17.2	17.8	17.5	18.1	18.4	17.2	17.8	17.5	18.1	18.4
	8H	17.2	17.8	17.5	18.1	18.4	17.2	17.8	17.5	18.1	18.4
	12H	17.1	17.7	17.5	18.0	18.3	17.1	17.7	17.5	18.0	18.3
4H	2H	17.3	18.0	17.6	18.3	18.5	17.3	18.0	17.6	18.3	18.5
	3H	17.2	17.8	17.5	18.1	18.4	17.2	17.8	17.5	18.1	18.4
	4H	17.1	17.6	17.5	18.0	18.3	17.1	17.6	17.5	18.0	18.3
	6H	17.1	17.5	17.5	17.8	18.2	17.1	17.5	17.5	17.8	18.2
	8H	17.0	17.4	17.4	17.8	18.2	17.0	17.4	17.4	17.8	18.2
	12H	17.0	17.3	17.4	17.7	18.1	17.0	17.3	17.4	17.7	18.1
8H	4H	17.0	17.4	17.4	17.8	18.2	17.0	17.4	17.4	17.8	18.2
	6H	16.9	17.2	17.4	17.6	18.1	16.9	17.2	17.4	17.6	18.1
	8H	16.9	17.1	17.4	17.6	18.1	16.9	17.1	17.4	17.6	18.1
	12H	16.8	17.1	17.3	17.5	18.0	16.8	17.1	17.3	17.5	18.0
12H	4H	17.0	17.3	17.4	17.7	18.1	17.0	17.3	17.4	17.7	18.1
	6H	16.9	17.1	17.4	17.6	18.1	16.9	17.1	17.4	17.6	18.1
	8H	16.8	17.1	17.3	17.5	18.0	16.8	17.1	17.3	17.5	18.0
Variation of the observer position for the luminaire distances S											
S = 1.0H		+2.0 / -4.9					+2.0 / -4.9				
S = 1.5H		+4.3 / -15.0					+4.3 / -15.0				
S = 2.0H		+6.3 / -17.6					+6.3 / -17.6				
Standard table		BK00					BK00				
Correction Summand		-1.1					-1.1				
Corrected Glare Indices referring to 446lm Total Luminous Flux											

The UGR values have been calculated according to CIE Publ. 117 Spacing-to-Height-Ratio = 0.25.