

Operator  
Telephone  
Fax  
e-Mail

## DMLUX verlichtingsarmaturen DM901279-840-FF Mylène 60x60 LED panel / UGR-Table

Luminaire: DMLUX verlichtingsarmaturen DM901279-840-FF Mylène 60x60 LED panel  
Lamps: 2 x LED STRIP

<b>Glare Evaluation According to UGR</b>											
$\rho$ Ceiling		70	70	50	50	30	70	70	50	50	30
$\rho$ Walls		50	30	50	30	30	50	30	50	30	30
$\rho$ Floor		20	20	20	20	20	20	20	20	20	20
Room Size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	17.2	18.0	17.4	18.2	18.4	19.2	20.1	19.5	20.3	20.5
	3H	17.1	17.8	17.3	18.0	18.3	19.2	19.9	19.5	20.2	20.4
	4H	17.0	17.7	17.3	18.0	18.2	19.1	19.9	19.5	20.1	20.4
	6H	16.9	17.6	17.2	17.8	18.1	19.1	19.8	19.4	20.0	20.3
	8H	16.9	17.5	17.2	17.8	18.1	19.1	19.7	19.4	20.0	20.3
	12H	16.8	17.4	17.2	17.7	18.1	19.1	19.7	19.4	20.0	20.3
4H	2H	17.1	17.8	17.4	18.1	18.3	19.1	19.8	19.4	20.1	20.3
	3H	17.0	17.6	17.4	17.9	18.2	19.1	19.7	19.4	20.0	20.3
	4H	17.0	17.5	17.3	17.8	18.2	19.1	19.6	19.5	19.9	20.3
	6H	16.9	17.3	17.3	17.7	18.1	19.1	19.5	19.5	19.9	20.2
	8H	16.9	17.2	17.3	17.6	18.0	19.1	19.4	19.5	19.8	20.2
	12H	16.8	17.2	17.3	17.6	18.0	19.1	19.4	19.5	19.8	20.2
8H	4H	16.9	17.3	17.3	17.7	18.1	19.0	19.4	19.4	19.8	20.2
	6H	16.8	17.1	17.3	17.5	18.0	19.0	19.3	19.4	19.7	20.1
	8H	16.8	17.0	17.2	17.5	17.9	19.0	19.2	19.4	19.7	20.1
	12H	16.7	16.9	17.2	17.4	17.9	19.0	19.2	19.5	19.7	20.1
12H	4H	16.9	17.2	17.3	17.6	18.0	18.9	19.3	19.4	19.7	20.1
	6H	16.8	17.0	17.2	17.5	17.9	18.9	19.2	19.4	19.6	20.1
	8H	16.7	16.9	17.2	17.4	17.9	18.9	19.1	19.4	19.6	20.1
Variation of the observer position for the luminaire distances S											
S = 1.0H		+3.0 / -6.7					+2.9 / -5.1				
S = 1.5H		+4.3 / -8.8					+5.4 / -6.9				
S = 2.0H		+6.1 / -10.5					+7.4 / -7.5				
Standard table		BK00					BK00				
Correction Summand		-1.4					0.8				
Corrected Glare Indices referring to 4192lm Total Luminous Flux											

The UGR values have been calculated according to CIE Publ. 117 Spacing-to-Height-Ratio = 0.25.