

OliNo Energy BV

Operator Marcel van der Steen
 Telephone
 Fax
 e-Mail marcel@olino.org

Abalight 1001398 SMART200 Flood CLU044-1212 CRI80 4000K / UGR-Table

Luminaire: Abalight 1001398 SMART200 Flood CLU044-1212 CRI80 4000K
 Lamps: 1 x LED

| Glare Evaluation According to UGR | | | | | | | | | | | |
|--|--------------|---|-----|-----|-----|--------------|--|-----|-----|-----|-----|
| ρ Ceiling | 70 | 70 | 50 | 50 | 30 | 70 | 70 | 50 | 50 | 30 | |
| ρ Walls | 50 | 30 | 50 | 30 | 30 | 50 | 30 | 50 | 30 | 30 | |
| ρ Floor | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | |
| Room Size X Y | | Viewing direction at right angles to lamp axis | | | | | Viewing direction parallel to lamp axis | | | | |
| 2H | 2H | 8.1 | 8.7 | 8.3 | 8.9 | 9.1 | 8.1 | 8.7 | 8.3 | 8.9 | 9.1 |
| | 3H | 8.0 | 8.6 | 8.3 | 8.8 | 9.1 | 8.0 | 8.6 | 8.3 | 8.8 | 9.1 |
| | 4H | 7.9 | 8.5 | 8.2 | 8.7 | 9.0 | 7.9 | 8.5 | 8.2 | 8.7 | 9.0 |
| | 6H | 7.9 | 8.4 | 8.2 | 8.7 | 9.0 | 7.9 | 8.4 | 8.2 | 8.7 | 9.0 |
| | 8H | 7.8 | 8.4 | 8.2 | 8.6 | 8.9 | 7.8 | 8.4 | 8.2 | 8.6 | 8.9 |
| | 12H | 7.8 | 8.3 | 8.2 | 8.6 | 8.9 | 7.8 | 8.3 | 8.2 | 8.6 | 8.9 |
| 4H | 2H | 7.9 | 8.5 | 8.2 | 8.7 | 9.0 | 7.9 | 8.5 | 8.2 | 8.7 | 9.0 |
| | 3H | 7.8 | 8.3 | 8.2 | 8.6 | 8.9 | 7.8 | 8.3 | 8.2 | 8.6 | 8.9 |
| | 4H | 7.8 | 8.2 | 8.1 | 8.5 | 8.9 | 7.8 | 8.2 | 8.1 | 8.5 | 8.9 |
| | 6H | 7.7 | 8.1 | 8.1 | 8.4 | 8.8 | 7.7 | 8.1 | 8.1 | 8.4 | 8.8 |
| | 8H | 7.7 | 8.0 | 8.1 | 8.4 | 8.8 | 7.7 | 8.0 | 8.1 | 8.4 | 8.8 |
| | 12H | 7.7 | 8.0 | 8.2 | 8.4 | 8.8 | 7.7 | 8.0 | 8.2 | 8.4 | 8.8 |
| 8H | 4H | 7.7 | 8.0 | 8.1 | 8.4 | 8.8 | 7.7 | 8.0 | 8.1 | 8.4 | 8.8 |
| | 6H | 7.6 | 7.9 | 8.1 | 8.3 | 8.7 | 7.6 | 7.9 | 8.1 | 8.3 | 8.7 |
| | 8H | 7.6 | 7.8 | 8.1 | 8.3 | 8.7 | 7.6 | 7.8 | 8.1 | 8.3 | 8.7 |
| | 12H | 7.7 | 7.8 | 8.1 | 8.3 | 8.8 | 7.7 | 7.8 | 8.1 | 8.3 | 8.8 |
| 12H | 4H | 7.6 | 7.9 | 8.1 | 8.3 | 8.7 | 7.6 | 7.9 | 8.1 | 8.3 | 8.7 |
| | 6H | 7.6 | 7.8 | 8.1 | 8.2 | 8.7 | 7.6 | 7.8 | 8.1 | 8.2 | 8.7 |
| | 8H | 7.6 | 7.8 | 8.1 | 8.2 | 8.7 | 7.6 | 7.8 | 8.1 | 8.2 | 8.7 |
| Variation of the observer position for the luminaire distances S | | | | | | | | | | | |
| S = 1.0H | +4.5 / -8.3 | | | | | +4.5 / -8.3 | | | | | |
| S = 1.5H | +7.2 / -11.3 | | | | | +7.2 / -11.3 | | | | | |
| S = 2.0H | +9.2 / -17.0 | | | | | +9.2 / -17.0 | | | | | |
| Standard table | BK00 | | | | | BK00 | | | | | |
| Correction Summand | -5.6 | | | | | -5.6 | | | | | |
| Corrected Glare Indices referring to 2870lm Total Luminous Flux | | | | | | | | | | | |

The UGR values have been calculated according to CIE Publ. 117 Spacing-to-Height-Ratio = 1.00.