

V-Fix-75Watt-ST

by

KLV Ledverlichting





Summary measurement data

parameter	meas. result	remark
Color temperature	4979 K	neutral white
Luminous intensity I_v	3375.3 Cd	Measured straight underneath the lamp.
Illuminance modulation index	0 %	Measured with a light sensor looking at the lamp (angle not defined). Is a measure for the amount of flickering.
Beam angle	118 deg	118 deg is the beam angle for the C0-C180-plane (perpendicular to the length direction of the lamp) and 116 deg is the beam angle for the C90-C270 plane, which is along the length direction of the lamp.
Power P	75.8 W	The net power consumed.
Power Factor	0.98	An electrical load with this power factor means that for every 1 kWh net energy consumed, there has been 0.18 kVAhr for reactive energy.
THD	8 %	Total Harmonic Distortion.
Max inrush current	4.989 A	This current has been found at a voltage start angle of 0 degrees.
Luminous flux	10111 lm	Measured with photogoniometer, calculation done as described in LM79-08.
Luminous efficacy	133 lm/W	
EU2013-label classification	A++	The energy class, from A++ (more efficient) to E (least efficient). This label is an update of the previous version, and compulsory from Sept 2013.
CRI_Ra	80	Color Rendering Index.
Qa_CQS	78.6	QCS (v9.0.3) is an improved indicator (over CRI) of how well colors are rendered.
Qg_CQS	0.88	Gamut Area Ratio.
Coordinates chromaticity diagram	x=0.3595 en y=0.3464	
Fitting	230V	This lamp is connected directly to the grid voltage.
PAR-value	30.4 uMol/s/m^2	The number of photons seen by an average plant when it is lit by the light of this light bulb. Value valid at 1 m distance from light bulb.
PAR-photon efficacy	1.2 uMol/s/W_e	The total emitted number of photons by this light, divided by its consumption in W. It indicates a kind of efficacy in generating photons.



parameter	meas. result	remark
Photon current	143.8 uMol/s	The total number of photons in the light of this lamp.
S/P ratio	2.0	This factor indicates the amount of times more efficient the light of this light bulb is perceived under scotopic circumstances (low environmental light level).
L x W x H external dimensions	1200 mm x 145 mm x 93 mm	External dimensions of the lamp.
L x W x H luminous area	1180 mm x 85 mm x 13 mm	Dimensions of the luminous area (used in Eulumdat file). It is the total area of the frosted LED tubes.
General remarks		The ambient temperature during the whole set of illuminance measurements was 25.4 - 26.7 deg C.The temperature of the lamp gets maximally about 15 degrees hotter than ambient temperature. Warm up effect: During the warmup time the illuminance doesn't vary significantly (< 5 %). During the warmup time the power doesn't vary significantly (< 5 %). The variation in efficacy (calculated as indication by simplydividing the illuminance by the power) during the warming up is -3 %. A very high negative value indicates a significant decrease for instance due to heating up of the lamp (decrease of lifetime). Voltage dependency: There is no (significant) dependency of the illuminance when the power voltage varies between 200 - 250 V AC. There is no (significant) dependency of the consumed power when the power voltage varies between 200 - 250 V AC. At the end of the article an additional photo.
Eff-variation	-3 %	This is the variation in efficacy (calculated as indication by simply dividing the illuminance by the power) during the warming up. A very high negative value indicates a significant decrease for instance due to heating up of the lamp (decrease of lifetime).
Dimmable	yes	Info from manufacturer.
Melanopic effect factor	0.683	According to norm DIN SPEC 5031-100:2015-08.
Blue Light Hazard risk group	0	0=exempt, 1=low, 2 = moderate, 3=high risk.
form factor	bar	
article number		



Overview table

	Ø5	50%	CO-180: 118°		Luminaire Efficacy
m.	C0-180	C90-270	C90-270: 116°	E (lux)	133 (lumen per Watt)
1	3.34	3.18		3375	Half-peak diam Co-180
1.5	5.02	4.77		1500	3.34 x diameter(m)
2	6.69	6.36		844	Half-peak diam C90-270
					3.18 × diameter(m)
3	10.03	9.53		375	Illuminance
4	13.38	12.71		211	3375 / distance (lux)
6	20.07	19.07		94	Total Output
8	26.76	25.42		53	10111 (lumen)

Please note that this overview table makes use of calculations, use this data with care as explained on the OliNo site. E (lux) values are not accurate, when within 5 x 1183 mm (maximal luminous size, eventually diagonally measured)= 5915 mm. Within this distance from the lamp (data given in red), the measured lux values will be less than the computed values in this overview as the measurements are then within the near field of the lamp.




EU 2013 Energy label classification

Since Sept 2013 these labels will be needed.

Important for the energy classification are the corrected rated power and the useful luminous flux.


The measured rated power is 75.8 W and might need to be corrected. The correction is dependent from the lamp type and whether or not the lamp control gear is included or not. The choice for this lamp is the following classification: **Lamps with own control gear** (external or internal). As a result the corrected rated power becomes: 75.8 W. The luminous flux measured is 10111 lm. The classification of this lamp needed to determine the useful flux is: **Non-directional lamps**. Then the useful flux becomes 10111 lm. Now a reference power can be calculated.

The energy efficiency coefficient is P_corr / P_ref = 0.10.



EU energy label for this lamp






The lamp's performance in the lumen-Watt field, with the energy efficacy fields indicated.



Eulumdat light diagram

This light diagram below comes from the program Qlumedit, that extracts these diagrams from an Eulumdat file.




The light diagram giving the radiation pattern.

The light diagram indicates the beam in the C0-C180 plane (perpendicular to the length direction of the lamp) and in the plane perpendicular to that, the C90-C270 plane (along the length direction of the lamp).



Illuminance Ev at 1 m distance, or luminous intensity lv Herewith the plot of the *averaged* luminous intensity lv as a function of the inclination angle

with the light bulb.




The radiation pattern of the light bulb.

This radiation pattern is the average of the light output of the light diagram given earlier. Also, in this graph the luminous intensity is given in Cd.

These averaged values are used (later) to compute the lumen output.





Intensity data of every measured turn angle at each inclination angle.

This plot shows per inclination angle the intensity measurement results for each turn angle at that inclination angle. There normally are differences in illuminance values for different turn angles. However for further calculations the averaged values will be used.

When using the average values per inclination angle, the beam angle can be computed, being 118 deg for the C0-C180 plane and 116 deg for the C90-C270 plane.

Luminous flux

With the averaged illuminance data at 1 m distance, taken from the graph showing the averaged radiation pattern, it is possible to compute the luminous flux.

The result of this computation for this light spot is a luminous flux of 10111 lm.

Luminous efficacy

The luminous flux being 10111 lm, and the consumed power of the lamp being 75.8 Watt, results in a luminous efficacy of 133 lm/Watt.




Electrical properties

The power factor is 0.98. An electrical load with this power factor means that for every 1 kWh net energy consumed, there has been 0.18 kVAhr for reactive energy.

Lamp voltage	230.18 V
Lamp current	0.335 A
Power P	75.8 W
Apparent power S	77.1 VA
Power factor	0.98


Of this lamp the voltage across and the resulting current through it are measured and graphed.



Voltage across and current through the lightbulb

This current waveform has been checked on requirements posed by the norm IEC 61000-3-2:2006 (including up to A2:2009).





Harmonics in the current waveform and checked against IEC61000-3-2:2006 and A2:2009

When the consumed power is 25 W there are limits for the harmonics and those are fulfilled.


The Total Harmonic Distortion of the current is computed and its value is 8 %.



Inrush current


The inrush current has been measured for different voltage start angles; from 0 - 170 degrees with a 10 degrees step. The current- and voltage values have been acquires at a sample speed of 39.9 kS/s. Then this data has been fed into a second order 2kHz low pass Butterworth filter. This removes the current spikes that do not represent relevant values. The lamp was two minutes off before every inrush current measurement was made.

Test voltage	230.0 V	
Frequency of the voltage	50.0 Hz	
Maximum inrush current	4.989 A	This current has been found at a voltage start angle of 0 degrees.
Pulse width of max inrush current	4.9E-3 s	This is the time that the pulse is higher than 10 % of the max inrush current.
Minimal inrush current	0.810 A	This current has been found at a voltage start angle of 150 degrees.
I^2 x t after 10 ms at 0 deg voltage start angle	5.408E-2 A	This is the I^2 t value when a zero crossing detector is used to start the voltage from 0 degrees.




Inrush current found at worst-case voltage start angle






First cycle of the maximum inrush current




The energy I^2t during the first 10 ms of the first current cycle



Temperature measurements lamp








Temperature image(s).

status lamp	2 hours on
ambient temperature	26.7 deg C
reflected background temperature	26.7 deg C
camera	Flir T335
emissivity	0.95
measurement distance	0.5 m
IFOV_geometric	0.136 mm per 0.1 m distance
NETD (thermal sensitivity)	50 mK



Color temperature and Spectral power distribution




The spectral power distribution of this light bulb, energies on y-axis valid at 1 m distance.

The measured color temperature is 4979 K which is neutral white.

This color temperature is measured straight underneath the light bulb. Below a graph showing the color temperature for different inclination angles.





Color temperature as a function of inclination angle.

The color temperature is given for inclination angles up to 90 deg. Beyond that angle has not been measured.


For the C0-C180 plane: the beam angle of 118 deg is equivalent to 59.1 deg inclination angle, which is the area where most of the light falls within. The maximum variation of color temperature in the first 90 degrees of this inclination area is about 4 %.

For the C90-C270 plane: the beam angle of 116 deg is equivalent to 57.8 deg inclination angle, which is the area where most of the light falls within. The maximum variation of color temperature in the first 90 degrees of this inclination area is about 5 %.



PAR value and PAR spectrum

To make a statement how well the light of this light bulb is for growing plants, the PAR-area needs to be determined.




The photon spectrum, then the sensitivity curve and as result the final PAR spectrum of the light of this light bulb

parameter	value	unit
PAR number	30.4	uMol/s/m^2
PAR photon current	91.0	uMol/s
PAR photon efficacy	1.2	uMol/s/W

The PAR efficiency is 65 % (valid for the PAR wave length range of 400 - 700 nm). This is the maximum percentage of the total of photons in the light that is effectively used by the average plant (since the plant might not take 100 % of the photons at the frequency where its relative sensitivity is 100 %).



S/P ratio




The power spectrum, sensitivity curves and resulting scotopic and photopic spectra (spectra energy content defined at 1 m distance).

The S/P ratio of the light coming from this lamp is 2.0.



Chromaticity diagram



The chromaticity space and the position of the lamp's color coordinates in it.

The point of the light in this diagram is inside the area indicated with class A. This area indicates an area for signal lamps.


The color coordinates are x=0.3595 and y=0.3464.



Color Rendering Index (CRI) or also Ra

Herewith the image showing the CRI as well as how well different colors are represented (rendered). The higher the number, the better the resemblance with the color when a black body radiator would have been used (the sun, or an incandescent lamp)

Each color has an index Rx, and the first 8 indexes (R1 .. R8) are averaged to compute the Ra which is equivalent to the CRI.



CRI of the light of this lightbulb.

This value of 80 indicates how well the light of this lamp can render well a set of reference colors, this in comparison with the light of a reference source (for color temperatures 5000K a black radiator is used as reference and for color temperatures 5000K the sun or the light outside during the day).

The value of 80 is equal to the value of 80 that is considered as a minimum for working areas in general.


Note: the chromaticity difference is 0.0034 and indicates the distance to the Planckian Locus. There is a value mentioned of max 5.4E-3 in section 5.3 of CIE 13.3-1995 however not further explanation of it.

An other reference with signal lights as a reference is given in the chromaticity diagram.




Color Quality Scale

(v9.0.3) is an improved indicator (over CRI) of how well colors are rendered.



CQS-values of the light of this light bulb.




CQS-values for the light of this light bulb compared with those of a reference source with the same color temperature.



Voltage dependency

The dependency of a number of lamp parameters on the lamp voltage is determined. For this, the lamp voltage has been varied and its effect on the following light bulb parameters measured: illuminance E_v [lx], the lamppower P [W] and the luminous efficacy [lm/W] (this latter is estimated here by dividing the found E_v value by P).



Lamp voltage dependencies of certain light bulb parameters

There is no (significant) dependency of the illuminance when the power voltage varies between 200 - 250 V AC.


There is no (significant) dependency of the consumed power when the power voltage varies between 200 - 250 V AC.


When the voltage varies abruptly with + or - 5 V AC then this results in a variation of the illuminance of maximally 0.0 %. This difference in illuminance is not visible (when it occurs abruptly).



Warm up effects

After switch on of a cold lamp, the effect of heating up of the lamp is measured on illuminance $E_v[x]$, the lamppower P[w] and the luminous efficacy [m/w].





Effect of warming up on different light bulb parameters. In the first graph the 100 % level is put at begin, and in the last graph the 100 % level is put at the end.




During the warmup time the illuminance doesn't vary significantly (5%).

During the warmup time the power doesn't vary significantly (5 %). The variation in efficacy (calculated as indication by simplydividing the illuminance by the power) during the warming up is -3 %. A very high negative value indicates a significant decrease for instance due to heating up of the lamp (decrease of lifetime).

Measure of flickering

An analysis is done on the measure of flickering of the light output by this light bulb.



The measure of fast illuminance variation of the light of the light bulb

parameter	value	unit
Flicker frequency	4207.1	Hz
Illuminance modulation index	0	%
Flicker index	0.000	[-]

The illuminance modulation index is computed as: (max Ev - min Ev) / (max Ev + min Ev).



Melanopic effect


The melanopic effect shows the level of impact the light of this lamp can have on the day-night rhythm of human beings (as well as the suppression of melatonin production). The important parameters (according to norm DIN SPEC 5031-100:2015-08):

melanopic effect factor	0.683
k_mel trans (25 years)	1.050
k_mel trans (32 years)	1.000
k_mel trans (50 years)	0.840
k_mel trans(75 years)	0.596
k_mel trans(90 years)	0.465
k_pupil(25 years)	1.088
k_pupil(32 years)	1.000
k_pupil(50 years)	0.792
k_pupil(75 years)	0.543
k_pupil(90 years)	0.416



Blue Light Hazard

The amount of blue light and the harm it can cause on the retina has been determined. Herewith the results.



The level of blue light of this lamp related to the exposure limit and the different classification areas.

L_lum0 [mm]	9	Dimension of brightest part of lamp in C0-C180 direction.
L_lum90 [mm]	472	Dimension of brightest part of lamp in C90-C270 direction.
SSD_500lx [mm]	2598	Calculated distance where Ev = 500 lux. This computation is valid when it is in the far field of the lamp. Note: if this value 200 mm then the distance of 200 mm is taken as proposed in the norm IEC 62471:2006.
Start of far field [mm]	2360	Minimum distance at which the lamp can be seen as apoint source. In this area the Ev is linearly dependent from (1/distance)^2.
300-350 nm values stuffed with 0s	yes	In the event OliNo has measured with a SpB1211 spectrometer without UV option then the irradiance data of 300-349 nm is missing. For lamps where there is already no energy content near 350 nm, the values 300-349 can also be set at zero then.
alpha_C0-C180 [rad]	0.003	(Apparent) source angle in C0-C180 direction.
alpha_C90-C270 [rad]	0.182	(Apparent) source angle in C90-C270 direction.



alpha_AVG [rad]	0.052	Average (apparent) source angle. If average >= 0.011 rad then the exposure limit is computed with radiance Lb. Otherwise with irradiance Eb.
Exposure value [W/m^2/sr]	8.63E+1	Blue Light Hazard value for this lamp, measured straight underneath the lamp. Computation is referenced to Lb.
Blue Light Hazard risk group	0	0=exempt, 1=low, 2 = moderate, 3=high risk.

Extra



Additional photos.

Disclaimer

The information in this OliNo report is created with the utmost care. Despite this, the information could contain inaccuracies. OliNo cannot be held liable in this instance nor can the data in this report be legally binding.

We strive to adhere to all of the conditions of any copyright holder in the publication of any illustration/article or item. In the event that we unintentionally violate said copyright holder's conditions in our articles, we kindly ask to be contacted here at OliNo so that we can resolve any disputes, issues or misunderstandings.

License

It is permitted ONLY to use or publish this report in its entirety and in unaltered form via internet or other digital or written media in any form. To guarantee the reliability and accuracy of the report, it is strictly prohibited to change or alter parts of the report and/or republish it in a modified content.