

Operator
Telephone
Fax
e-Mail

Casablanca Leuchten GmbH FO31-LD231A3 Casablanca FOLLOX 3S low-voltage-LED / UGR-Table

Luminaire: Casablanca Leuchten GmbH FO31-LD231A3 Casablanca FOLLOX 3S low-voltage-LED
Lamps: 1 x LED

Glare Evaluation According to UGR											
ρ Ceiling	70	70	50	50	30	70	70	50	50	30	
ρ Walls	50	30	50	30	30	50	30	50	30	30	
ρ Floor	20	20	20	20	20	20	20	20	20	20	
Room Size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	17.6	18.8	18.2	19.4	20.0	16.8	18.0	17.4	18.6	19.2
	3H	19.7	20.8	20.3	21.4	22.1	18.3	19.4	18.9	20.0	20.7
	4H	20.7	21.7	21.3	22.3	23.1	19.0	20.0	19.6	20.6	21.3
	6H	21.7	22.6	22.3	23.3	24.0	19.4	20.4	20.1	21.0	21.7
	8H	22.1	23.0	22.8	23.7	24.4	19.6	20.5	20.2	21.1	21.9
	12H	22.6	23.4	23.2	24.1	24.8	19.7	20.6	20.4	21.2	22.0
4H	2H	18.2	19.2	18.8	19.8	20.6	17.6	18.6	18.2	19.2	19.9
	3H	20.5	21.4	21.2	22.0	22.8	19.3	20.2	20.0	20.9	21.6
	4H	21.7	22.5	22.4	23.1	23.9	20.1	20.9	20.8	21.6	22.4
	6H	22.8	23.5	23.5	24.2	25.0	20.7	21.4	21.4	22.1	22.9
	8H	23.4	24.0	24.1	24.7	25.6	20.9	21.6	21.7	22.3	23.1
	12H	23.9	24.5	24.6	25.2	26.1	21.1	21.7	21.9	22.4	23.3
8H	4H	22.0	22.6	22.7	23.3	24.2	20.6	21.3	21.4	22.0	22.8
	6H	23.4	23.9	24.1	24.6	25.5	21.5	22.0	22.2	22.8	23.6
	8H	24.1	24.5	24.8	25.3	26.2	21.8	22.3	22.6	23.1	24.0
	12H	24.8	25.2	25.5	25.9	26.9	22.1	22.5	22.9	23.3	24.2
12H	4H	22.0	22.6	22.7	23.3	24.2	20.7	21.3	21.5	22.1	22.9
	6H	23.4	23.9	24.2	24.7	25.6	21.7	22.2	22.5	22.9	23.8
	8H	24.2	24.6	25.0	25.4	26.3	22.2	22.6	22.9	23.3	24.3
Variation of the observer position for the luminaire distances S											
S = 1.0H	+0.1 / -0.1					+0.1 / -0.1					
S = 1.5H	+0.2 / -0.2					+0.2 / -0.3					
S = 2.0H	+0.3 / -0.4					+0.3 / -0.6					
Standard table	BK09					BK07					
Correction Summand	8.4					5.5					
Corrected Glare Indices referring to 540lm Total Luminous Flux											

The UGR values have been calculated according to CIE Publ. 117 Spacing-to-Height-Ratio = 0.25.